



White Hill Wind Farm Electricity
Substation & Electricity Line

Environmental Impact
Assessment Report

Annex 12.4: Gas Pipeline
Electrical Interference
Assessment

White Hill Wind Limited

Galetech Energy Services

Clondargan, Stradone, Co. Cavan Ireland

Telephone +353 (0)49 555 5050

www.galetechenergyservices.com





ELECTRICAL INTERFERENCE TO ADJACENT PIPELINES UNDER NORMAL AND AC FAULT CONDITIONS WHITE HILL WIND FARM

Document History

Rev	Date	Reason for Issue	Prepared	Checked	Approved	Review	Review	Approved
3	23/02/25	Cable Route & Executive Summary Amendments	DS	KCL	KCL			
2	21/10/24	Drawing Amended	DS	KCL	KCL			
1	18/09/24	Drawings added	KCL	KCL	KCL			
0	02/09/24	First Issue	KCL	MJH	KCL			
			Corroconsult			Client		

Contract & Report Details

CCL Project Reference:	6999	CCL Variation Number:	N/A			
Category	Code	Description				
Location Code:	WWF	White Hill Wind Farm				
Document Type:	REP	Report				
System Number:	GNI	Unknown pipeline				
Life Cycle:	N/A	Life Document				
Location	System	CCL Job No.	Doc. Type	Sequence	Revision	Total
WWF	GNI	6999	REP	1	3	11

Contents

Introduction	3
Executive Summary	3
Documents used in the Assessment	3
Relevant Standards	3
Scope	4
Background	4
Electrical Interference	4
Normal Operation	4
Inductive	4
Conductive	4
Fault Conditions	4
Conductive	4
Mitigation Measures	5
Recommended Course of Action	6
Appendix A – Background Information	7
Appendix B – Drawings	9

Introduction

There is a risk of electrical interference to the GNI pipeline where the two 33 kV circuits cross the pipeline.

Executive Summary

- Based on the assumptions made the level of induced AC interference during normal operation is acceptable.
- Based on the assumptions made the Earth Potential Rise is neither harmful to the pipeline coating nor is it an electric shock risk
- Baseline datalogging and soil resistivity measurements should be undertaken.
- With the new cable route advised, as long as the cables are in HDPE ducts, laid in trefoil formation and cross at an angle between 90 degrees and 45 degrees, the original assessment is still valid.

Documents used in the Assessment

Table 1 Documents used in the Assessment

Ref.	Title	Description
230222/KB/WH/001 Rev. 00	White Hill Wind Farm Cable route and GNI pipeline	Cable and pipeline Route
230118/KS/GOR/001 Rev.001	Cable and existing GNI pipeline	Cable crossing
BGE/AL/06/74/RD/66	Cork-Dublin Gas Pipeline As-laid road crossing minor No.66	RDX details

Relevant Standards

BS EN ISO 21857:2021	Petroleum, petrochemical, and natural gas industries – Prevention of corrosion on pipeline systems influenced by stray currents.
BS EN ISO 8044:2015	Corrosion of metals and alloys – Basic terms and definitions.
BS EN ISO 15589-1:2015	Petroleum, petrochemical, and natural gas industries – cathodic protection of pipeline transportation systems – Part 1: On-land pipelines.
BS EN ISO 18086:2020	Corrosion of metals and alloys. Determination of AC corrosion. Protection criteria.
CEN 12954:2019	General principles of Cathodic protection of buried or immersed metallic structures.
BS EN 50443:2012	Effects of electromagnetic interference on pipelines caused by high voltage AC electric traction systems and/or high voltage AC power supply systems
IEEE Std 80:2013	Guide for Safety in AC Substation Grounding
ENA EREC S34 Issue 2	A guide for assessing the rise of earth potential at electrical installations

IEC/TS 60479-1:2005	Effects Of Current On Human Beings And Livestock Part 1; General Aspects
NACE SP0177:2019	Mitigation Of Alternating Current And Lightning Effects On Metallic Structures And Corrosion Control Systems

Scope

Assess the risk of electrical interference to the adjacent pipeline at the road crossing.

Background

The proposed cables will be in trefoil formation and within non-conductive ducts. There will be two 33 kV circuits, and they will be buried for the entire route.

Electrical Interference

There are two interference mechanisms from the buried cable; induction during normal operation and conductive during fault conditions.

Inductance, during normal operation, can result in induced AC voltage in the pipeline. Under some conditions these induced voltages can cause, or exacerbate, external corrosion.

Normal Operation

Inductive

Induced voltage calculations are in accordance with EN ISO 21857 and relate to situations where the interfering source is parallel to the pipeline. In this case the buried cable crosses the pipeline at approximately 45 degrees, the induced effect is small.

Furthermore, the cables are laid in trefoil formation, which substantially reduces the electromagnetic radiation.

The short crossing length, combined with the trefoil formation, means that the induced voltage will be within acceptable limits. Theoretically, the induced voltage is less than 1 V rms.

Conductive

Significant conductive interference occurs only under fault conditions. This interference does not directly lead to corrosion (due to the short duration).


Fault Conditions

Conductive

If the earth potential rise at the pipeline exceeds the dielectric strength of the coating it can change the coating performance characteristics, which could encourage future corrosion. Further investigation is required if the earth potential rise at the pipeline is greater than 5 kV for two or three layer polyethylene coatings (i.e. GNI pipelines).

Calculations show that under fault conditions at the substation the Earth Potential Rise (EPR) is less than 0.5 kV, which is below the threshold of 3 kV – 5 kV, and this means that it is an acceptable level. These values will change with different soil resistivities.

Figure 1 EPR Plot for 8 kA and 10 kA



Personnel Safety

The risk to personnel arises only when they make physical contact with the pipe. Since the pipe is buried the only possibility to touch the pipe is at the existing test posts, where the pipe connection is connected to a stud on the outside of the test post. The EPR of less than 0.5 kV and the duration (0.3 s) means that no special precautions are required at the test posts or above ground appurtenances.

Mitigation Measures

Inductive Interference

Existing electrical interference on the pipeline is unknown. This will be verified when the baseline measurements are performed.

Based on the theoretical AC interference from the buried cable under normal operating conditions there will not be a requirement for mitigation.

Acceptable levels of interference are specified in EN ISO 18086. Assessing the interference levels for AC corrosion risks is not straightforward, but the first step is to reduce the voltage level to less than 15 V rms.

Conductive Interference

Under fault conditions the Earth Potential Rise has been estimated from the assumptions of the fault current, soil resistivity, and separation distance.

Table 2 Earth Potential Rise Parameters

Parameter	Value	Unit	Source
Fault Current	8	kA	Energia
Distance from centre to edge of earth grid	25	m	Assumed
Distance from edge of grid to pipeline	290	m	Scaled from map
Substation earth resistance	0.5	Ohms	Assumed
Soil resistivity	50	Ohm.m	Assumed
Rise of earth potential	220	V	Calculated

Regardless of the theoretical induced voltages and earth potential rise it is possible that GNI will require for any existing coating defects on the pipeline in the vicinity of the substation to be exposed and repaired.

Recommended Course of Action

This analysis is based on assumptions and experience, and can only serve as a guide to what the interference is likely to be.

There are four steps that need to be completed after the planning approval has been received.

Step 1

Carry out datalogging on the GNI test posts close to the substation. Logging shall be with satellite synchronized dataloggers on a two second sample for a period of at least 5 days, and including a weekend day. AC and DC pipe-to-soil potentials will be measured. This data will provide a baseline against which future interference will be assessed. At the same mobilisation, soil resistivity values will be measured.

Step 2

Another set of calculations should be completed when the detailed electrical design has been approved and the assumptions eliminated from the calculations in this assessment. If the new values are not within acceptable limits, then mitigation methods will need to be designed. Mitigation designs will require GNI approval. It is also possible that GNI will require permanent remote monitoring close to the substation.

Step 3

Repeat the baseline measurements during the commissioning of the system to verify that the interference is at acceptable levels.

Step 4

Continuous AC and DC pipe-to-soil potentials should be remotely monitored at two existing test posts closest to the crossings to ensure that there are no operational changes or system deterioration that adversely affects the integrity of the pipeline. The system should be compatible with the existing GNI remote monitoring system.

Appendix A – Background Information

Figure 1 shows the concepts of touch potentials.

Table 5 is an extract from EN 50443, which shows the recommended separation distance for electromagnetic interference.

The fault current values associated with insulating and resonant earth systems are low and do not result in danger or in significant risk of damage or disturbance, and calculations or measurements are only required when interference occurs.

Table 3 shows a typical situation when work is carried out by trained and experienced personnel. The safe limits are based on the fault clearance time (IEC/TS 60479-1).

Table 3 Safe Limits

Fault Duration (s)	Interference voltage (V rms)
$t \leq 0.1$	2000
$0.1 < t \leq 0.2$	1500
$0.2 < t \leq 0.35$	1000
$0.35 < t \leq 0.5$	650
$0.5 < t \leq 1.0$	430
$1.0 < t \leq 3.0$	150
$t > 3$	60

Corrosion Risk

Due to the short duration of fault currents, they are not a direct corrosion risk. Indirectly, however, excessive voltages can cause coating stress which will alter the corrosion protection performance of the coating.

To prevent damages to the pipeline or to the connected equipment, and in the absence of site specific calculations, the following conditions apply:

Conducting coupling from AC power supply systems shall be considered in case or proximity lower than:

- 5m from then closest visible part of the tower of an HV power line rated at 50 kV or less
- 20m from the closest visible part of the tower of an HV power line provided with earth wires with nominal voltage greater than 50 kV
- 100m from the closest visible part of the tower of a HV power line not provided with earth wires with nominal voltage greater than 50 kV
- 20m from earthing systems of HV power cables with nominal voltage greater than 50 kV
- 150m from the earthing grid of a power substation.

Table 4 NACE SP 0177 Recommended coating stress voltage limits

Coating	Coating Stress Voltage Limit (kV)
Bitumen	1 – 2
Coal tar and asphalt	3
FBE and polyethylene	3 – 5

Figure 2 Extract from IEEE80




Figure 12—Basic shock situations

Table 5 Extract from BS 50443

Type of AC Power System	Areas	Resistivity ($\Omega \cdot m$)	Interference Distance (m)	
			Normal Operation	Fault Condition
Overhead	Rural	> 3000	Resistivity/3	Resistivity
		\leq 3000	1000	3000
Overhead	Urban	> 3000	\geq 300	Resistivity/10
		\leq 3000		\geq 300
Buried	All	All	50	50

